

SECTION 10151 - CUBICLE CURTAIN ENCLOSURE**PART 1 - GENERAL****1.1 RELATED DOCUMENTS**

- A. The general provisions of the contract, including General and Special Conditions and General Requirements, apply to the work specified in this section.

1.2 DESCRIPTION OF WORK

- A. The following type of application is specified in this section:
1. Ceiling Mounted Track.
 2. Fire Proof Curtain.

1.3 QUALITY ASSURANCE

- A. Provide cubicle curtain track as manufactured by the following or equal:
1. Imperial Fasteners Co.
 2. Beltor.
 3. Cubicle Co., Inc.
 4. Hillrom.
 5. Grant.
 6. A.R. Nelson.
 7. OB/Masco Track
 8. General Cubicle Co.
 9. Watrous.
- B. Products: Provide cubicle curtain as manufactured by the following or equal:
1. Maharam.
 2. Coral of Chicago.
- C. Fire-Rating: The cubicle curtain shall be permanently flame resistant. Identify each curtain with label indicating type of fabric construction.

1.4 SUBMITTALS

- A. Shop Drawings: Cubicle Track
1. Submit shop drawings for the fabrication and installation of cubicle track. Include details of track type, layout and installation instructions. Show anchorage and accessory items.
- B. Samples, Curtain:
1. Submit samples of each color. Contracting Officer's Representative's review of samples will be for color, texture and pattern only.
- C. Product Delivery, Storage and Handling:
1. Deliver tracks and curtained cartoned to provide protection during transit and job storage.

PART 2 - PRODUCTS**2.1 MATERIALS**

- A. Suspended track shall be extruded aluminum box-channel 35 mm x 19 mm slotted on the underside to receive two wheeled carriers. End closers shall be used at both ends of the cubicle with a removable section at one end to permit removal of hoods. Butt joints shall be secured by an extruded sleeve type connection of the same material and finish as the track. The hooks shall be formed of rust proof wire and bead chain riding on a carrier with non-wearing nylon wheels.
- B. Cubicle curtains shall be by Coral of Chicago "CPQ-4." High count construction 62 x 42 count, 1,800 mm wide, 100% F.R. Polyester, machine washable to 71 degrees C, inherently flame retardant and will pass fire code NFPA #701. Extend curtain to within 25 mm of the floor. Curtain shall be 10% wider than the track on which they hang. Also approved is Maharam Healthcare Collection 4.

PART 3 - EXECUTION**3.1 INSTALLATION**

- A. Install track units and curtains in accordance with final shop drawings and manufacturer's data, and as herein specified.

END OF SECTION 10151